

Attached or detached garages with electric power Minimum Requirements

- 1. A GFCI receptacle E 3801.9
- 2. A light in garage E 3803.3
- 3. A light outside the entry doors (not garage doors) E 3803.3
- 4. Main disconnect required * 225-31
(if more than one circuit) E 3301.2

8' ground rods
6' apart

