



1. The service can be on all sectionals
2. You must have four insulated conductors for feeders
3. You must have additional spaces in the service panel for wells, etc.
4. Over six circuits in main panel requires a main breaker
5. The service must be at least as big as the panel in the home
6. You must have a light in the crawl space by the equipment with the switch by the access door
7. Your equipment must have a disconnect within sight or be lockable
8. Conductors must be in conduit when above ground